ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ___ APPLICATION DATE ___
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ DATE EVALUATED: 2-26-02
LOCATION OF SITE: Lot 100 pk. 2 Pamlico Cove PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	wkSAB brn scl	frssp					.13
		6-33	SAB R/dL	frssp	f/p brn/gry/mott sl/sap at 18" common lit at 30"				.9
		33-41	wk AB-mane L sap	fr sssp					.15
		41-63	gy/brn/mane SL sap	fr ss-nss np					
2		0-5	wkSAB brn scl	frssp					
		5-19	SAB R/dL	frssp sap					
		19-33	wkSAB gy/dL common lit sap	frssp					.3
		33-60	wk SAB V L sap	frssp					
3		0-4	gy-wkSAB brn scl	frssp					.3
		4-13	SAB R/dL	frssp					.9
		13-21	wk AB scl sap	frssp					.15
		21-32	pbrn L/SL sap	frss-nss np					
		32-66	brn SL sap	frss-nss np					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___
COMMENTS: ___