DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICATION DATE _____
ADDRESS: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 3-1-82
LOCATION OF SITE: Lot 115 Sec 2 Brush Glen Subd PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5 1		0-4	gr-wk sbk bn sdl fr						
		4-23	sbk/ab rck L fr sss/p	common brn mottles	few dk 3/4 dia mottles				.25
		23-40	wk ab prsm common mn sbk/p fr sss/p						6 3+
		40-59	LSM/p fr sss/p						
6 2		0-6	gr brn sdl fr sss/p						
		6-24	sab clay fi fr sss/p						.3
		24-62	wk sbk/ab prsm L fr sss/p sk/p		few-common mn brn & few-common dk brn mottles & irregular shape				
7 3		0-12	gr brn sdl fr sss/p						
		12-34	sab cl fi fr sp sk/p		few gray & brn mottles & irregular shape				.3
		34-42	wk sbk/sab prsm cl fr sss/p						
		42-57	LSM/p fr sss/p						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____