DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #: 5770
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: L. NOSKAR
ADDRESS: 1628 SHEARERS RD. DAVIDSON NC
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360 GPD
LOCATION OF SITE: SAME
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

APPLICATION DATE
DATE EVALUATED: 5/28/15
PROPERTY SIZE: 1.6 ACRE
PROPERTY RECORDED: —

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
A 1	LL 6%	0-40	RC, ABK	FI, SS, SP	Y/B MOTTLES 32"-39". CHROMA 2's 40"+	46"	N/A	48"	.25 ABOVE 46"
A 2	LL 8%	0-36	RC, ABK	FI, SS, SP	Y/B MOTTLES 24"-33" CHROMA 2 @ 34"	36"	E-L SAP INCL. 18"-36"	34"	.25 ABOVE 34"

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PR
System Type(s)	APPROVED	APPROVED
Site LTAR	.25	EXISTING

OTHER FACTORS (.1946): —
SITE CLASSIFICATION (.1948): TS
EVALUATED BY: SHANE POSHON
OTHER(S) PRESENT: L. NOSKAR

COMMENTS:

Need Transmission from Tower Co. to Run Supply Line under T/W

Alice Evans Locations