IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 / 130.00 Paid MOORESVILLE 704-664-5

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM I

PERMIT# 130835 PIN# ~~4664-57-2559.031~~ 4664566438.000 DATE Sept

OWNER OR CONTRACTOR Anniston, LLC PHONE: Business 704 362-5007 Home

ADDRESS 17824 Statesville Rd, Suite 112, Cornelius, N.C. 28031

LOCATION Shearers Rd (S) TL Anniston Way TR Logans Crossing Dr. on Right near end

SUBDIVISION Anniston BLOCK / SECTION LOT 31/31A LOT AREA 1.976Ac+.395Ac SFE SITE CLASS. PS SFE DESIGN FLOW 480gpd L.T.A.R. .25 SFE 31A

Septic Tank: 1000 Gallons; STB 825 Date 9/20/08
Pump Tank: 1000 Gallons; PT 302 Date
Pump Make: ZOELLER Model E-191B Serial No.
Nitrification Field: No Fields 1 Square Feet 1620 Linear Feet 540
No Lines 6@90' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: PM 25% Reduction TB
Repair System Description: LP 25% Reduction
Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms
☐ Business No. Employees
☐ Other

Gravel Depth NA
☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions:
Initial site evaluation and system design performed by Rollins Soil and Environmental Services

Comments/Conditions: Driveway to be moved to right side. House may be moved back some from plan. A.C. 5/29/08
Tank lines + pressure checked by W.S.

INITIAL SITE SKETCH

See Plan by Ashley Rollins

AS BUILT SKETCH

Electric checked 1/13/09 A.C.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lori Tomaszewski date 9-7-05 Installed by: Rowan Septic Tank

Improvement Permit by: date 9-7-05 Operation Permit by: Anthony Coker R.S. date 1/13/09

Authorization to Construct by: Anthony Coker date 5/29/08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK