# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 130836 PIN# ~~4694 54 2559~~ 4664566796.000 DATE 6/5/07

OWNER OR APPLICANT Cunniston LLC / WHITLEY CO. PHONE: Business 704 362 5007 Home

ADDRESS 17824 Statesville Rd. Ste 112 Cornelius, NC, 28031

LOCATION Sheares Rd. TL Cunniston Way TR Logans Crossing Dr. on (R) near end.

SUBDIVISION Cunniston BLOCK / SECTION 1 LOT 33 LOT AREA 1.74 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .2

Septic Tank: 500 Gallons; STB 338 Date 9/7/07

Pump Tank: 1000 Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1800 Linear Feet 600

No Lines 6 Trench Width 3 Max Trench Bottom Depth 18" Gravel Depth No ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: PM → 25% Reduction

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments./Conditions: Trench depth 18" maximum. Installer have Rollers to Pocketon site at all times.

Comments:/Conditions: EZ FLOW INSTALLED. GRAVITY + DIST. BOX. Type II

INITIAL SITE SKETCH

FAST TRACK BY ROGERS SOIL & ENVIRONMENTAL

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X [signature] date 6/6/07

Improvement Permit by: Wesley Sparks R.S. date 6/5/07

Authorization to Construct by: Wesley Sparks R.S. date 6/12/07

Installed by: Holloman Const.

Operation Permit by: Wesley Sparks R.S. date 11/20/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK