IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 174666 PIN # 4664569019 DATE 10/29/12

OWNER or APPLICANT CHAD GOODEN STG. HOMES PHONE: Business Home: 704-363-7302

OWNER or APPLICANT ADDRESS 915A RIVER HWY MOORESVILLE 28117

LOCATION / DIRECTIONS SHEARERS RD - TR ANNISTON - TR LOGAN CROSSING - AT END

SUBDIVISION ANNISTON BLOCK / SECTION LOT # 29 LOT AREA 2.83AC DESIGN FLOW 600GPD L.T.A.R. 1,256 GPD

Septic Tank ~~1500~~ 1500 Gallons: STB 444 Date 10-1-12

Pump Tank ~~1000~~ 1500 Gallons: PT 477 Date 9-19-12

Pump Make MYERS Model ME50 Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 600

Trench Width 36" Max. Trench Bottom Depth 30" Gravel Depth MA

☑ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: PUMP 25% REDUCTION

Repair System Description: LP 25% REDUCTION / PTBPS

Maintenance Agreement Required ☐ YES ☑ NO


☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 5 ☐ Business No. Persons 10 ☐ Other No. Employees ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions

INITIAL SITE SKETCH



Comments / Conditions


The proposed / existing POOL addition does not appear to impact the existing septic system.

**NOTE: KEEP POOL 15' FROM SUPPLY LINE

C. Rymer R.S.

Date: 4/23/13

ICHD-Environmental Health Division



Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 11/06/2012 Installed by: RICHARD ABERNATHY

Improvement Permit by: C. Rymer Date 10/29/12 Operation Permit by: RA 1008 Date: 6-12-13

Authorization to Construct by: C. Rymer Date 10/29/12 Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant