DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: 17824 Statesville Rd., Suite 112/Cornelius, NC 28031
PROPOSED FACILITY: RES
LOCATION OF SITE: Anniston lot 25A
PROPOSED DESIGN FLOW (.1949): 480
APPLICATION DATE 8/05
DATE EVALUATED: 05
PROPERTY SIZE:
PROPERTY RECORDED: YES

WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P25A 1	Linear 5-10%	0-6	BCL GR	FRI SSSP SEXP	N/A	51	N/A	N/A	PS .25 GPD/FTSQ
		6-38	DKBC ABK	FRI SP SEXP					
		38-51	RBC MABK	FRI SP SEXP					
				MANG. INC					
P25B 2	Linear 5-10%	0-6	RBC ABK	FRI SP SEXP	N/A	56	N/A	N/A	PS .25 GPD/FTSQ
		6-56	YRCL MFSBK	FRI SSSP SEXP					
P25C 3	Linear 5-10%	0-6	BCL GR	FRI SSSP SEXP	N/A	52	N/A	N/A	PS .25 GPD/FTSQ
		6-52	DKBC ABK	FRI SP SEXP					
		0-10	wk sbk pbe vfr sssp						3
		10-26	sbk 80mlc fr sssp sopp						
		26-51	wk sbk rd fr sssp						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)	1500 SQFT	1140 SQFT
tem Type(s)	25% RED	LP PPBPS
LTAR	.25 GPD/FTSQ	.25 GPD/FTSQ

MENTS:

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollans Soil and Environmental Services
OTHER(S) PRESENT: Freeman/Rollans