SLOPE TO POOL - ADJUST VANE ZONE ACCORDINGLY

COPY

1.00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 123787 PIN# 4664 67 0878.037 4664-57-4190 DATE 5/5/05

OWNER OR CONTRACTOR RIDGELINE DEVELOPMENT PHONE: Business 362-5007 Home

ADDRESS 17105 KEATON DR. SUITE 207-C CORNELIUS NC 28031

LOCATION SHEARINGS RD (S) - TL ANNISTON - JR LOGAN - SEPTIC ON RT - T R ELIZABETH - LOT ON LT

SUBDIVISION ANNISTON BLOCK / SECTION 1 LOT 37 LOT AREA 1.33 AC SITE CLASS. PS DESIGN FLOW 480GPD L.T.A.R. .256 GPD/FT

Septic Tank: 1000 Gallons; STB Mariner Date

Pump Tank: 1000 Gallons; PT Mariner Date

Pump Make: Goulds Model WE 1512HH Serial No.

Nitrification Field: No Fields 1 Square Feet 660 Linear Feet 330

No Lines (6) Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPP PANEL OFFSITE

Repair System Description: LPP ONSITE

Maintenance Agreement Required: ☑ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions:

Comments:/Conditions:

-STE PT → Mariner Installed (1000 Gal)

INITIAL SITE SKETCH 1" = 100'

AS BUILT SKETCH 1" = 40'

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 5-17-05 Installed by: Marty Tucker (Tucker's Grading)

Improvement Permit by: [signature] date 5/5/05 Operation Permit by: [signature] date 11/21/06

Authorization to Construct by: Wesley Sparks RS. date 11/23/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK