IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 / 130.00 Paid / MOORESVILLE 704-664-5281 3:30

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 130837 PIN# 4664572559.034 4664 57 6091 DATE Sept. 7, 05

OWNER OR CONTRACTOR Anniston LLC PHONE: Business 704 362-5207 Home

ADDRESS 17824 Statesville Rd. Suite 112, Cornelius, N.C. 28031

LOCATION Shearers Rd. (S) to I-77 Anniston Way TR Logans Crossing Dr. on Right past jct w/ Elizabeth Brooke Dr.

SUBDIVISION Anniston BLOCK / SECTION LOT 34/34A LOT AREA .81Ac ± .49Ac SFE SITE CLASS. PS SFE DESIGN FLOW 450gpd L.T.A.R. .025 SFE 34A

Septic Tank: 1000 Gallons; STB 825 Date 4-19-11

Pump Tank: 1000 Gallons; PT 302 Date 5-14-11

Pump Make: ZOELLER Model E191 Serial No. 7HP

Nitrification Field: No Fields 1 Square Feet 1575 Linear Feet 525

No Lines 7 @ 75' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: On 25% Reduction on 34A

Repair System Description: LPP PBPS on 34A

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

Clinical site evaluation and system design performed by Rollins Soil and Environmental Services.

Comments:/Conditions:

Must Keep ST/PT at least 50'+ from Pond well

INITIAL SITE SKETCH

SEE PLAN by Ashley Rollins

AS BUILT SKETCH

Approved Acc. Building 5-24-11

Septic Installer To Know Where Building Will Be Before Instalation.

Building Installed Before Septic

Zer Pressure Head Set

The proposed / existing Pool addition does not appear to impact the existing septic system.

**NOTE: Shall be min. 15' from septic Tank & Pump

See Site Plan

Amanda Melville R.S.

Date: November 8, 2012

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lori Tomashwski date 9-27-05

Improvement Permit by: RA Hollis REHS date 9-7-05

Authorization to Construct by: RA Hollis REHS date 12-1-10

Installed by: Bowan Septic

Operation Permit by: RA Hollis REHS date 7-6-11

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK