DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC _____ APPLICATION DATE 8/05
ADDRESS: 17824 Statesville Rd., Suite 112/Cornelius, NC 28031 DATE EVALUATED: 05
PROPOSED FACILITY: RES PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Anniston lot 34A PROPERTY RECORDED: YES
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
34A 1	Linear 5%	0-5	BSCL FWSBK	FRI SSSP SEXP	N/A	54	N/A	N/A	PS .25 GPD/FTSQ
		8-54	RC ABK	FRI S P SEXP					
				MANG.					
34B 2	Linear 5%	0-53	RC ABK	FRI S P SEXP	N/A	53	N/A	N/A	PS .25 GPD/FTSQ
				MANG.					
P2 3	Linear 5%	0-12	CL MWSBK	FRI SSP SEXP	N/A	54	N/A	N/A	PS .275 GPD/FTSQ
		12-42	RC MSBK	FI S P SEXP					
		42-54	ROC WSBK	S P FI SEXP					
				YB'S					
P24 4	Linear 5%	0-8	BCL MWSBK	FRI SSP SEXP	N/A	53	N/A	N/A	PS .275 GPD/FTSQ
		8-46	RC MABK/ABK	FRI SSP SEXP					
		46-53	ROCL FABK	FRI SSP SEXP					
				ROCK FRAGS					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1575 SQFT	1260 SQFT
System Type(s)	25% RED	LP PPBPS
Site LTAR	.25 GPD/FTSQ	.25 GPD/FTSQ

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollans Soil and Environmental Services
OTHER(S) PRESENT: Freeman/Rollans

COMMENTS: