DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC _____ APPLICATION DATE 8/05
ADDRESS: 17824 Statesville Rd., Suite 112/Cornelius, NC 28031 DATE EVALUATED: 05
PROPOSED FACILITY: RES PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Anniston lot 26A PROPERTY RECORDED: YES
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
A 1	Linear 5-10%	0-10	BSCL GR	FRI SSSP SEXP	N/A	56	N/A	N/A	PS .25 GPD/FTSQ
		10-29	DKBC ABK	FRI SP SEXP					
		29-56	RBC ABK	FRI SP SEXP					
B 2	Linear 5-10%	0-29	RBC ABK	FRI SP SEXP	N/A	55	N/A	N/A	PS .25 GPD/FTSQ
		29-55	YRCL MFSBK	FRI SSSP SEXP					
P9 3	Linear 5-10%	0-18	DKBCL FSBK	FRI SSSP SEXP	N/A	56	N/A	N/A	PS .3 GPD/FTSQ
		18-56	RC SBK/ABK	FI SS P SEXP					
A 4		0-6	wk sbk/wk fr ssp sp						.25
		6-55	wk sbk/wk fr ssp sp						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1440 SQFT	1095 SQFT
System Type(s)	25% RED	LP PPBPS
Site LTAR	.25 GPD/FTSQ	.25 GPD/FTSQ

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollans Soil and Environmental Services
OTHER(S) PRESENT: Freeman/Rollans

COMMENTS: