DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC _____ APPLICATION DATE 8/05
ADDRESS: 17824 Statesville Rd., Suite 112/Cornelius, NC 28031 DATE EVALUATED: 05
PROPOSED FACILITY: RES PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Anniston lot 27A PROPERTY RECORDED: YES
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 24 1	Linear 17%	0-13	BSCL GR	FRI SSSP SEXP	N/A	60	N/A	N/A	PS .3 GPD/FTSQ
		13-27	RBCL WSBK	FRI SP SEXP					
		27-60	RC ABK/SBK	FRI SS SP SEXP					
				FEW RELIC					
P 26 2	Linear 17%	0-12	DBCL FWSBK	FRI SS SP SEXP	N/A	60	N/A	N/A	PS .3 GPD/FTSQ
		12-26	RBSC L WSBK	FRI SS SP SEXP					
		26-60	RC SBK	FRI SS SP SEXP					
				FEW RELIC					
P 27 3	Linear 17%	0-12	BSCL GR	FRI SSSP SEXP	N/A	56	N/A	N/A	PS .3 GPD/FTSQ
		12--26	RBSC L WSBK	FRI SS SP SEXP					
		26-56	RC SBK	FRI SS SP SEXP					
P 28 4	Linear 6%	0-12	BSCL GR	FRI SS SP SEXP	N/A	50	N/A	N/A	PS .3 GPD/FTSQ
		12-21	RBSC L WSBK	FRI SS SP SEXP					
		21-50	RC SBK	FRI SS SP SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1200 SQFT	1500 ~~1200~~ SQFT
System Type(s)	25% RED	25% Red. ~~[illegible]~~
Site LTAR	.3 GPD/FTSQ	.3 GPD/FTSQ

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollans Soil and Environmental Services
OTHER(S) PRESENT: Freeman/Rollans

COMMENTS: