IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

315.00

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# B6625 174785 PIN# 4664-67-8995.076 4664674808 DATE Sept. 28, 06

OWNER OR APPLICANT Anniston LLC / Passarelli PHONE: Business _____ Home _____

ADDRESS 17824 Statesville Rd, Suite 112 Cornelius, N.C. 28031

LOCATION Shearers Rd (S) TL Anniston Way on Right after crossing creek

SUBDIVISION Anniston BLOCK / SECTION _____ LOT 76 LOT AREA 1.49 AC SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. @ 225

Septic Tank: 1000 Gallons; STB 794 Date 2-27-13

Pump Tank: 1000 Gallons; PT 327 Date 2-27-13

Pump Make: Myers Model ME50S Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1080 Linear Feet 360

No Lines 5 Trench Width 36"X Max Trench Bottom Depth 30"

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

X PER plan Specs. Keep drainfield laterals shallow (30" max trench bottom)
9/4/12 Reviewed Floor plans in Compliance with original plans.

INITIAL SITE SKETCH

Note: Tanks 50ft to well & 24ft to edge of swimming pool.

SEE Plan from Rolling Soil & Env. Services

Comments:/Conditions:

X House moved back slightly but should have enough room for septic & entire house still fits within 70'X70' House box

AS BUILT SKETCH

3/28/13 Tanks Checked.

4/3/13 Checked lines, installed

Location of the proposed in ground swimpool addition does not appear to impact the existing on-site septic system.**NOTE: Pool cut will be >15ft to Septic System

Maina Dolson REHS

Date: 3/28/13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kori Dailey date 10-10-06 Installed by: R&R

Improvement Permit by: _____ date 9-28-06 Operation Permit by: RA Ellis date 5-17-13

Authorization to Construct by: _____ date 9/4/12 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW