DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bluto Builders
ADDRESS: _____ APPLICATION DATE 6/08
PROPOSED FACILITY: 4 BRM PROPOSED DESIGN FLOW (.1949): 480 gpd DATE EVALUATED: 6/08
LOCATION OF SITE: Anniston Subdivision Lot 73 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
B73A	LSS	0-4	B CL WFSBK	SS, SP, Fr SExP	—	30"	UN	30"	PS
1 & 2	8-12%	4-15	R C MF/WFSBK	SS, SP, Fr SExP					
		15-30	R CL WFSBK	SS, SP, Fr SExP	com Sap				.25 to 30"
		30-48	YR CL Sap Mass	SS, SP, Fr SExP	many R C vens mixed mineral common olivine				
B73B	LSS	0-4	B CL WFSBK	SS, SP, Fr SExP	—	23"	UN	23"	PS
1 & 2	10-15%	4-18	R C MF/WFSBK/ABK	SS, SP, Fi-Fr SExP	few Sap				
		18-23	RB CL WFSBK	SS, SP, Fr SExP	com Sap				.25 to 23"
		23-48	Var. CL Sap Mass	SS, SP, Fr SExP	com R C vens mixed mineral common olivine				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPPBPS	Drip Irrigation
Site LTAR	0.25	0.1

OTHER FACTORS (.1946): None
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: ALP
OTHER(S) PRESENT: None

COMMENTS: _____