4664676875 375.00 3:00 - 4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 136824 PIN# ~~4664676875~~ 4664676875.000 DATE Sept 29, 06

OWNER OR APPLICANT Anniston LLC Shea Builders PHONE: Business _____ Home _____

ADDRESS 17824 Statesville Rd. Suite 112, Cornelius, N.C. 28031

LOCATION Shearers Rd. (5) TL Anniston Way on Right at jct w/ Burnell Place

SUBDIVISION Anniston BLOCK / SECTION _____ LOT 15 LOT AREA 1.850 AC SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. #25

Septic Tank: 1000 Gallons; STB 825 Date 2-10-14

Pump Tank: 1000 Gallons; PT 302 Date 1-19-14

Pump Make: Goulds Model N-152 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1470 Linear Feet 490 ✱

No Lines 7@70' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM 25% Reduction

Repair System Description: LPP PBPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons _____ No. Employees _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

✱ Per plan specs

Comments:/Conditions:

9/17/13 Reviewed floor plans in compliance with approved Septic plan. Bonus room (bunk beds) Are NOT fixed.

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

1/2 inch SCH 80 TANKS

CHECKED APR 04 2014

TANKS

LINES

SET 2 PM

ELECTRICAL FLOATS ALARM ✓ 10/14/14 SC

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Roni Dalley date 10-10-06

Improvement Permit by: _____ date 9-29-06

Authorization to Construct by: _____ date 9/17/13

Installed by: _____

Operation Permit by: _____ date APPROVED OCT 14 2014

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK