IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

3-3:30

PERMIT# 13821 PIN# 4664678995.057 4664-67-8858

OWNER OR APPLICANT Anniston LLC / N. Block DATE August 8, 2006

ADDRESS 7824 Statesville Rd, Suite 112, Cornelius, N.C. 28031 PHONE: Business Home

LOCATION Shearers Rd. (S) 1/2 mile into Anniston on R Creek on Right, at intersection with Burnett Pl

SUBDIVISION Anniston BLOCK / SECTION LOT 57 LOT AREA .850 Ac SITE CLASS. A5 DESIGN FLOW 600 gpd L.T.A.R. .275 initial

Septic Tank: 1500 Gallons; STB 3358 Date 12/24/06

Pump Tank: 1500 Gallons; PT 477 Date 11/23/07

Pump Make: Gould's Model WEA-511N Serial No.

Nitrification Field: No Fields 1 Square Feet 1650 Linear Feet 550

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI SB

System Description: 3m 25% Reduction

Repair System Description: LPP PBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 5 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions: Lp/w-Pm

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Don Oakley

Improvement Permit by: date 9-17-06

Authorization to Construct by: Judy Melville date 9-12-06

Installed by: Larry Henderson

Operation Permit by: Wesley Jenkins R.S. date 3/7/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK