3500 ✓

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14463 203357 PIN# 4664667997.059 4664679415 DATE July 24, 2007

OWNER OR APPLICANT Anniston LLC / Niblock Development PHONE: Business _____ Home _____

ADDRESS 17825 Statesville Rd, Suite 112, Cornelius, N.C. 28031

LOCATION Shearers Rd. South TL Anniston Way TR Burnell on left

SUBDIVISION ANNISTON BLOCK / SECTION _____ LOT 59 LOT AREA 1.68 Ac+ is 73,054 sq ft SITE CLASS. BSFE DESIGN FLOW 600gpd L.T.A.R. .25 (SFE)

Septic Tank: 1500 * Gallons; STB 338 Date 1-28-14
Pump Tank: 1500 * Gallons; PT 477 Date 1-28-14
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1800 Linear Feet 600
No Lines 6@100' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II IIIa IV V VI
System Description: pm 25% Reduction
Repair System Description: LPP BPS
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 5
☐ Mobile Home No. Persons ____
☐ Business No. Employees ____
☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
* Per plan specs
5/15/14 Reviewed Floor plans, in Compliance with original Septic plan.

INITIAL SITE SKETCH

SEE Plan from Rollins Soil + Env. Services

Comments:/Conditions: *Must keep tanks at least 40Ft to PL
Permit for 5 Bedrooms, application is for 4 Bedrooms, plan shows 4 Bedrooms

AS BUILT SKETCH

9/16/14 Checked tanks & Supply line.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Rod Calley date 8-7-07
Improvement Permit by: _____ date 7-24-07
Authorization to Construct by: _____ BS date 5/15/14

Installed by: Larry Hankle
Operation Permit by: _____ date 9-26-14
Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK