IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

$315.00 Ck. 9 3107

PERMIT# 136822 PIN# 4664 67 8995 . 058 4664-67-9657 DATE October 19, 2006

OWNER OR APPLICANT ~~Anniston LLC~~ / BLUTO BLDRS. PHONE: Business _____ Home _____

ADDRESS 17824 Statesville Rd, Suite 112, Cornelius, N.C. 28031

LOCATION Sheares Rd (S) TL Anniston Way TR Burnell Place 2nd Lot on left

SUBDIVISION Anniston BLOCK / SECTION _____ LOT 58 LOT AREA .95Ac SITE CLASS. PS DESIGN FLOW 600gpd L.T.A.R. .025

Septic Tank: 1500 ✓ Gallons: STB 338 Date 9/9/07

Pump Tank: 1500 ✓ Gallons: PT 477 Date 9/10/07

Pump Make: Ideal S Model WE05 II H Serial No. 10/1/07

Nitrification Field: No Fields 1 Square Feet 1200 * Linear Feet 400

No Lines 6 Trench Width 36" * Max Trench Bottom Depth 36"

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other

No. Bedrooms 5 No. Persons ____ No. Employees ____

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth NA [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions:

* PER plan specs

Comments:/Conditions: 10/22/07 - Checked top 5 lines (320') Lacks 1 - 90' line

Pressure Sets 11/13/07 AC

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lori Oakley date 10-24-06

Improvement Permit by: D. Swann, RS date 10-19-06

Authorization to Construct by: John E. Akers date 5-5-07

Installed by: A-1

Operation Permit by: Wesley Sparkes date 10/11/07

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK