TMENT OF ENVIRONMENT AND NATURAL RESOURCES
SION OF ENVIRONMENTAL HEALTH
SITE WASTEWATER SECTION

Sheet 1 of _
PROPERTY ID #: Lot# 58
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
PROPOSED FACILITY: 5-bedroom
PROPOSED DESIGN FLOW (.1949): 600gpd
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
APPLICATION DATE: 7/13/06
DATE EVALUATED: 5/06
PROPERTY SIZE: 0.95ac
PROPERTY RECORDED:
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
3		0-6	B SCL Gr	SS, SP, Fr, SEHP	—	58	—	—	PS
		6-22	RB C MAHK/SCL	SS, SP, Fr, SEHP					
		22-58	R CL WSPK	SS, SP, Fr SEHP	common FP				
6									.295
2									.25
3									.275
4									.25

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS:

DIVISION OF ENVIRONMENTAL HEALTH AND NATURAL RESOURCES
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 58
COUNTY: Iredell

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd APPLICATION DATE 7/13/06
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek DATE EVALUATED: 5/06
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY SIZE: 0.95ac
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut PROPERTY RECORDED:
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
D 3 6	5% L	0-6	gr brwsdl	frssso					.275
		6-22	mABK RedBrnc	slfr fssp scp					
		22-58	wkSBK pebl	frsssto fpl common scp					
2		0-8	wkSBK brnsdl	frssso					.25
		8-27	ABK redbrnc	fr sssp scp					
		27-38	mSBK red c +scp	fr fssp	few mica scp				
		38-54	wkSBK red +scp	fr sssp pl	common scp				
3		0-3	gr brwsdl	frssso					.25-.3 (.275 AS)
		3-19	ABK red c	frssso					
		19-37	SBK red c	fr sssp	few micl scp				
		37-56	wkSBK red cl +scp	fr sssp					
D	4% L	0-9	wkSBK brnsdl	frssso					.25
		9-40	mod BK brwn c	fr sssp scp	few manganiferous conc.				
		40-54	wkSBK red cl	frssp	few common scp				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	LPPPBRS	LPPPBRS
Site LTAR	.25	.25

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: