MENT OF ENVIRONMENT AND NATURAL RESOURCES
ION OF ENVIRONMENTAL HEALTH
SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 56
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
APPLICATION DATE 7/13/06
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd
DATE EVALUATED: 5/06
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
PROPERTY SIZE: 0.94ac
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
PROPERTY RECORDED:
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
3 2	L / 10-15%	0 – 40	BRC MFABK	FR SS P SEXP	FEW-COMM SAP	52"	N/A	N/A	PS 0.275 GPD/FT2
		40 – 52	RCL WSBK	FR SS SP SEXP					
2	L 5-10%	0-9	RB SCL WSBK	SS, SP, Fr SEXP	—	53	—	—	PS .275-.3
		9-32	RC MFABK/SBK	SS SP, FrSEXP					
		32-53	RCL WSBK	SS, SP, Fr SEXP	few/common SAP				
3	L 5-10%	0-5	B SCL Gr	SS, SP, Fr SEXP	—	54	—	—	PS .3
		5-19	RC MFSBK	SS, SP, Fr SEXP	few/common SAP				
		19-35	RC MFSBK	SS, SP, Fr SEXP					
		35-54	RCL WSBK	SS, SP, Fr SEXP	common SAP & RCL Veins				
4	L 5-10%	0-7	B SCL Gr	SS, SP, Fr SEXP	—	61	—	—	PS .275-.3
		7-18	RCL MSBK	SS SP, Fr SEXP					
		18-61	RCL VWFSBK	SS, SP, Fr SEXP	common SAP				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: