11:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138094 PIN# 4664689744.097 Home 4664-68-3768 DATE Jan 18, 2007

OWNER OR APPLICANT Anniston LLC / Marilyn Nicklow PHONE: Business 6063-1594 Home 704 658-4107

ADDRESS 17825 Statesville Rd Suite 112, Cornelius, N.C. 28031

LOCATION Stevens Rd. (S) TL Anniston Way TL Timberside Dr. TL Hanover Ct. on left at end

SUBDIVISION Anniston BLOCK / SECTION 3 LOT 97 LOT AREA 3.4Ac+ .3Ac SFE SITE CLASS. FS SFE DESIGN FLOW 600gpd L.T.A.R. .25 SFE

Septic Tank: 1500 Gallons; STB 444 Date 3-11-08

Pump Tank: 1500 Gallons; PT 477 Date 3-23-08

Pump Make: Gould Model PE712 Serial No.

Nitrification Field: No Fields 1 Square Feet 1245 * Linear Feet 415 *

No Lines 6 Trench Width 36"* Max Trench Bottom Depth 86" Gravel Depth 12" ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

3/4HP

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPPPBPS

Repair System Description: LPPIBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 5 No. Persons 10 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: * Use In Line Filter in PT

* Per Plan Specs.

Intercepter Drain Required.

Comments:/Conditions: 11/15/07 Okay to put well further back; behind & to side of house

7/31/08 Set 2ft pressure head

INITIAL SITE SKETCH

SEE Plan from Rollins Soil and Env. Services

AS BUILT SKETCH

5/2/08 Checked lines, installed As Drawn. Checked tanks too.

5-8-08 Checked French Drain SA

The proposed / existing Pergola addition does not appear to impact the existing septic system.

**NOTE: See site Plan-Shall be min. 5' from tanks

Judy Melville R.S.

Date: 10-15-12

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ / Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Michael Bedford date 2-13-07 Installed by: Richard Abernathy

Improvement Permit by: [signature] date 1-18-07 Operation Permit by: [signature] date 5/1/08

Authorization to Construct by: Judy Melville date 10-15-07 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK