10:15

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

PERMIT# 138096 PIN# 4664 689744.094

OWNER OR APPLICANT Anniston LLC / N Block 4664-68-8869

ADDRESS 17825 Statesville Rd. Suite 112, Cornelius, N.C. 28031 PHONE: Business _____ Home _____ DATE Jan 16, 2007

LOCATION Shearers Rd. (S) Tl. Anniston Way Tl. Timberside Dr. Tl. Hanover Lane on Right

SUBDIVISION Anniston BLOCK / SECTION _____ LOT 99 LOT AREA 1.4ac SITE CLASS. PS DESIGN FLOW 600gpd L.T.A.R. .025

Septic Tank: 1500 Gallons: STB 1500 Date 8-10-07

Pump Tank: 1500 Gallons: PT 477 Date 8-21-07

Pump Make: Goulds Model WE07124 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 600

No Lines 5@120' Trench Width 36" Max Trench Bottom Depth 36"

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: PM 25% Reduction

Repair System Description: LPP BDS

Maintenance Agreement Required: [ ] Yes [X] No

Gravel Depth N/A [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

[X] House/Mod. Home No. Bedrooms 5

[ ] Mobile Home No. Persons ____

[ ] Business No. Employees ____

[ ] Other _____

Water Supply: [X] Individual [ ] Public [ ] Community

Comments:/Conditions:

Well must be at least 25' from building foundation.

Comments:/Conditions: Sch 80 for tap on 1st line due to it being shorter.
9/27/07 Check all tanks & lines
10/3/07 25# pressure set

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Installed Quick 4 Drainfield, essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [X] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____

Improvement Permit by: _____ date 2-15-07

Authorization to Construct by: _____ date 6-16-07

_____ date 6/20/07

Installed by: Larry Hankers

Operation Permit by: _____ date 10/3/07

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK