DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: Lot# 50
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC — APPLICATION DATE: 7/13/06
ADDRESS: Anniston Way — DATE EVALUATED: 5/06
PROPOSED FACILITY: 5-bedroom — PROPOSED DESIGN FLOW (.1949): 600gpd — PROPERTY SIZE: 0.82ac
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek — PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut — TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5	L / 5-10%	0 - 43	RC ABK	FI S P SEXP	-FEW CHR. ¾'S	54"	N/A	N/A	PS 0.275 GPD/FT2
		43 – 54	RC MFABK	FI S P SEXP					
6 B	L / 5-10%	0 - 42	BSC WSBK	FR S P SEXP	-FEW [Mn] -FEW YB'S	60"	N/A	N/A	PS 0.275 GPD/FT2
		42 - 60	BRC MFABK	FR SS SP SEXP					
(7)	7-18-06 7-85	0-6	wk sbk brn sl	fr sss p					.225-.25
		6-24	sbk/mabk cl	fr sss p					
		24-45	ABK red c	fr sp sss p sexp					
		45-56	w-m mabk cl-sicl	fr sss p					
		0-25	wk sbk red c	fr sss p sexp					.225-.25
		25-31	wk mabk red c	fr sp sexp	common yellow mottles				
		31-46	wk mabk red c	fr sss p	few common sap plus common yellow mottles				
		46-56	wk sbk red cl	fr sss p	common p				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: