IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 142149 PIN # 4664 76 1644 DATE 5-29-12

OWNER Bluto Builders/Steadman APPLICANT: same PHONE: Home/Cell # 704-202-8035 Business #

SITE ADDRESS 169 Burnell Place, Davidson 28036 OWNER / APPLICANT ADDRESS 17005 Green Dolphin Lane Cornelius, NC 28031

SITE DIRECTIONS Sheavers Rd TL Anniston Way TR Burnell at end on left

SUBDIVISION Anniston BLOCK / SECTION 2 LOT # 65 LOT AREA .93 Ac. DESIGN FLOW 600gpd L.T.A.R. .3gpd/ft²

Septic Tank 1500 Gallons: STB 1014 Date 1-14-12
Pump Tank 1500 Gallons: P T 4164 Date 12-20-11
Pump Make Zoeller Model N152 Serial # 4HP
No. Nitrification Fields: 1 No. Lines 7 Linear Feet 340
Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI
System Description: LP PPBPS
Repair System Description: LP PPBPS
Maintenance Agreement Required ☒ YES ☐ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 5
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Keep Drainfield lines 15' from 2' embankment
Pool shall be min. 15' from septic system

INITIAL SITE SKETCH

See Plan from
Rollans Soil & Environmental
Services
Approved by ICHD

AS BUILT SKETCH

INSTALLED
AS
DRAWN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** with plat valid without expiration. ☒ ***IMPROVEMENT PERMIT*** with ~~plat valid without expiration.~~ site plan valid 60 mo. ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.

Owner / Applicant Signature: [signature] Date 5/30/12 Installed by: ROWAN SEPTIC

IMPROVEMENT PERMIT by: Andy Melville REHS Date 5-29-12 OPERATION PERMIT by: [signature] REHS Date 7-2-12

AUTHORIZATION TO CONSTRUCT by: Andy Melville REHS Date 5-29-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant