IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 159477 PIN # 4664-77-8456 DATE 1-6-10

OWNER or APPLICANT NIBLOCK DEVELOPMENT PHONE: Business 704-920-7125 Home:

OWNER or APPLICANT ADDRESS 300 MCGILL AVE CONCORD NC

LOCATION / DIRECTIONS SHEARERS, TL ANNISTON WAY, TR BURNELL, TL WALKING HORSE, ONL

SUBDIVISION ANNISTON BLOCK / SECTION LOT # 119 LOT AREA .748AC DESIGN FLOW 600GPD L.T.A.R. .3

Septic Tank 1500 Gallons: STB 338 Date 8-509

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 4 Linear Feet 500'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: GRAVITY 25% REDUCTION

Repair System Description: PM 25% REDUCTION

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 5 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 1) INSTALL PER PLAN SPECS

Comments / Conditions

INITIAL SITE SKETCH

ADS 5' CHAMBERS LINE LENGTHS INSTALLED AS SHOWN. SEE DRAWING FOR DISTRIBUTION

ARC 36"

SEE PLAN FROM ROLLANS SOIL + ENVIRONMENTAL SERVICES APPROVED BY ICHD RA

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 1/7/10

Improvement Permit by: R. A. Reis Date 1-6-10

Authorization to Construct by: R. A. Reis Date 1-6-10

Installed by: LARRY HINKLE

Operation Permit by: R. A. Reis Date: 3-6-10

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant