DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 51
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

APPLICATION DATE 7/13/06
DATE EVALUATED: 5/06
PROPERTY SIZE: 0.95ac
PROPERTY RECORDED:
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
7	L / 5-10%	0 - 45	BSC FABK/SBK	FR SS SP SEXP	-COMM [Mn]	54"	N/A	N/A	PS
		45 – 54	RC WMABK	FI S P SEXP	-FEW [Mn]				0.25 GPD/FT2
8	L / 5-10%	0 - 45	BC SBK	FR SS SP SEXP		60"	N/A	N/A	PS
		45 - 60	RCL MFABK	FR SS SP SEXP	-COMM SAP				0.275 GPD/FT2
(9)		0-28	wk-m sbk vfr dk	fr ss sp					.275
		28-40	abk vfr dk	fi fr ss sp					
		40-56	wk sbk cl-stk sp	fr ss sp					
(10)	Mod L	0-34	wk sbk red brn sdy cl	fr ss sp					.3
		34-52	sbk red cl	fr ss sp so p					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS:

...MENT OF ENVIRONMENT AND NATURAL RESOURCES
...N OF ENVIRONMENTAL HEALTH
...SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 51
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
APPLICATION DATE 7/13/06
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd
DATE EVALUATED: 5/06
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
PROPERTY SIZE: 0.95ac
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
PROPERTY RECORDED:
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	L / S-10%	0 - 45	BSC FABK/SBK	FR SS SP SEXP	-COMM [Mn]	54"	N/A	N/A	PS
		45 – 54	RC WMABK	FI S P SEXP	-FEW [Mn]				0.25 GPD/FT2
	L / S-10%	0 - 45	BC SBK	FR SS SP SEXP	-COMM SAP	60"	N/A	N/A	PS
		45 - 60	RCL MFABK	FR SS SP SEXP					0.275 GPD/FT2
									.275
									.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		
ystem Type(s)		
te LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

MMENTS: