DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: Lot# 102
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC APPLICATION DATE 10/6/06
ADDRESS: Anniston Phase 3 DATE EVALUATED: 8/06
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd PROPERTY SIZE: ac
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way, Lt. Timberside Dr. PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 102A	HS 0-5%	0-9	B CL WSBK	Fr SS,SP SEXP	—	52"	—	—	PS
		9-27	BRC MSBK/MASK	Fr SS,SP SEXP					0.275-.3
		27-52	RCL WSBK	Fr SS,SP SEXP	-common SP				
2		0-31	m-wk m mk C	fr SSSP	few ch 3/4				.25
		31-55	wk m sbk C	fr ss sp	common SP				
			Best @ 36"						
3		0-25	m-wk m mk C	fr SSSP					.25
		25-54	wk m sbk/mk	C fr SSSP	few prom				
			water seeping in pit						
4	10% +	0-30	wk m mbk/sbk	C fr SSSP					.275
		30-50	wk m sbk	C fr ss sp	few common SP				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: