Fixed 10:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138/04 PIN# 4664 689744.103 4664-78-1959 DATE Jan 16, 2007

OWNER OR APPLICANT Anniston LLC / Nidock PHONE: Business _____ Home _____

ADDRESS 17825 Statesville Rd, Suite 112, Cornelius, N.C. 28031

LOCATION Stevens Rd (S) to Anniston Way to Timbersite Dr. on left past Hanover Ct.

SUBDIVISION Anniston BLOCK / SECTION 3 LOT 103 LOT AREA .74 Ac SITE CLASS PS DESIGN FLOW 600gpd L.T.A.R. .25

Septic Tank: 1500 Gallons; STB 338 Date 12-23-07

Pump Tank: 1500 Gallons; PT 477 Date 8-4-07

Pump Make: Goulds Model PE51M Serial No. _____ 1/2 HP

Nitrification Field: No Fields 1 Square Feet 1200 * Linear Feet 400

No Lines 6 Trench Width 36" * Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III ⓘ V VI

System Description: LPPBDS

Repair System Description: LPPBDS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 5 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* Per Plan Specs

Comments:/Conditions: Drilled 5/32" hole

Installed essentially as Drawn

3/14/08 Alarm, tanks, lines & pressure (2nd)

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ / Improvement Permit with site plan valid for sixty months ☒

Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 2-13-07

Improvement Permit by: [signature] date 1-16-07

Authorization to Construct by: [signature] date 1-11-08

Installed by: Larry Hendrix RS

Operation Permit by: [signature] date 4/29/08

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK