DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 103
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Phase 3 APPLICATION DATE 10/6/06
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd DATE EVALUATED: 8/06
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way, Lt. Timberside Dr. PROPERTY SIZE: ac
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY RECORDED:
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P	LSS	0-36	RB C HABK	Fr SS, SP SEXP	—	45"	PS	—	PS
03A	6-10%	36-45	R C WABK	Fi SS, P SEXP	-Common Sap				
		45-53	Verig LS Sap Rock	Fr SS, SP SEXP	-Common Clay incl.				0.25
2		0-17	wk mod sbk cl	fr SSSP					
		17-40	m wk mod sbk cl	fr SSSP SOP					.25
		40-58	wk massive cl	fr SSSP SOP					
3	15% L	0-10	wk mod sbk scl	fr SSSP					
		10-40	m wk mod sbk cl	fr SSSP SOP					.25-.275
		40-54	m wk mod sbk sicl	fr SSP					
4	10% L	0-5	wk sbk scl	fr SSSP					
		5-24	wk mod sbk c	fr SSSP SOP					.25
		24-54	m fiabk mod pl cl	fr SSP SOP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: