DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: Lot# 52
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

APPLICATION DATE 7/13/06
DATE EVALUATED: 5/06
PROPERTY SIZE: 0.72ac
PROPERTY RECORDED:
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1 4	L / 5-10%	0 - 22	RC MFABK	FR SS SP SEXP		58"	N/A	N/A	PS
		22 – 58	RCL WMSBK	FR SS SP SEXP					0.3 GPD/FT2
(2)		0-2 2-30 30-62	gr fsl sl/sd wk sbk rd c wk sbk rd cl	fr ss sp fr ss sp SEXP fr ss sp					.3
(3)		0-4 4-27 27-57	wk sbk gr sdl wk sbk rd c wk sbk rd cl	fr ss sp fr ss sp SEXP fr ss sp		few common SOP			.3
(4)		0-2 2-15 15-48	gr fsl sl/sd sbk c wk sbk cl (BC)	fr ss sp fr ss sp SEXP fr ss sp		common SOP			.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: