DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: Lot# 52
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Way
PROPOSED FACILITY: 5-bedroom
PROPOSED DESIGN FLOW (.1949): 600gpd
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way across creek
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
APPLICATION DATE 7/13/06
DATE EVALUATED: 5/06
PROPERTY SIZE: 0.72ac
PROPERTY RECORDED:
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
14	L / 5-10%	0 - 22	RC MFABK	FR SS SP SEXP		58"	N/A	N/A	PS
		22 – 58	RCL WMSBK	FR SS SP SEXP					0.3 GPD/FT2
15									.3
16									.3
17									.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: