IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138121 PIN# 4664 68 9744.117 4664-78-3494 DATE 8/22/07

OWNER OR APPLICANT Niblock Homes PHONE: Business 704-788-4818 Home

ADDRESS 300 McGill Ave. NW Concord, N.C. 28027

LOCATION Sheeres Rd TL Anniston Way TL Timberside Dr. Left on R

SUBDIVISION Anniston BLOCK / SECTION LOT 117 LOT AREA .72 AC SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 312 Date 1-17-07

Pump Tank: 1000 Gallons: PT 27 Date 8-25-07

Pump Make Goulds Model PE5IM Serial No.

Nitrification Field: No Fields 1 Square Feet 801 Linear Feet 267

No Lines 5 (Sand Filter) Width 3' Max Trench Bottom Depth 3' Gravel Depth No ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ New System ☐ Repair ☐ Expansion System Type: I II III ⓘ V VI

System Description: Pressure Dosed - 16" PPBPS

Repair System Description: Same Type

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions: Follow site plan closely. 5/32" hole drilled 65 holes Total 10/24/07 Tanks checked by A.C

Comments/Conditions: Installed essentially as Drawn 10/30/07 Checked lines, pressure & level.

INITIAL SITE SKETCH

Fast Track Plan prepared by Rollins Site & Environmental Services. No Modification without ICHD approval.

Rollins Plan must be on site during installation.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X Joann Key date 10-3-07

Improvement Permit by: Wesley Sparks R.S. date 8/22/07

Authorization to Construct by: Wesley Sparks R.S. date 8/22/07

Installed by: Larry Hinkle

Operation Permit by: Mark Dotson RS date 11/21/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK