**IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH*** ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

**IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION**

PERMIT # 17134 PIN # 4677-57-1590 DATE 4-11-12

OWNER KENNETH CHRISTIANA APPLICANT: SAME PHONE: Home/Cell # Business #

SITE ADDRESS 1307 OAKRIDGE HWY OWNER / APPLICANT ADDRESS SAME

SITE DIRECTIONS

SUBDIVISION BLOCK / SECTION LOT # LOT AREA .87AC DESIGN FLOW 360 L.T.A.R. .4

Septic Tank 1000 Gallons: STB 794 Date 2-19-12

Pump Tank Gallons: P T Date

Pump Make Model Serial #

No. Nitrification Fields: 1 No. Lines 2 Linear Feet 224'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: G. 25%

Repair System Description: 25%

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing

No. Bedrooms 3 No. Persons No. Employees ☒ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

The proposed / existing ADDITION & BUILDING RELOCATION addition does not appear to impact the existing septic system.


**NOTE:

R.S.

Date: 8-30-12

ICHD-Environmental Health Division

INITIAL SITE SKETCH




INSTALLED AS SHOWN

*Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.*

☐ ***IMPROVEMENT PERMIT*** with plat valid without expiration. ☐ ***IMPROVEMENT PERMIT*** with plat valid without expiration. site plan valid 60 mo. ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date 4/11-12 Installed by: LARRY BEAM

IMPROVEMENT PERMIT by: REHS Date 4-11-12 OPERATION PERMIT by: REHS Date 4-25-12

AUTHORIZATION TO CONSTRUCT by: REHS Date 4-11-12 Existing System Inspected by: REHS Date

***YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION***

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant