DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* 1
PROPERTY ID #: Lot# 115
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Anniston, LLC
ADDRESS: Anniston Phase 3 APPLICATION DATE 10/6/06
PROPOSED FACILITY: 5-bedroom PROPOSED DESIGN FLOW (.1949): 600gpd DATE EVALUATED: 8/06
LOCATION OF SITE: Shearer's Road, Lt. on Anniston Way, Lt. Timberside Dr. PROPERTY SIZE: ac
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY RECORDED:
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P 115A	LSS 0-5%	0-28 28-50	BRC msbk/pbk RCL wsbk	FrSS,SP,SEXP FrSS,SP,SEXP	— - Common Sap	50"	—	—	PS 0.7-0.35
(2)		0-27 27-43 43-57	SM msbk c wk sbk cl Massive LSap	fr SSSP SEXP fr SSSP w/ some mica fr SSSP w/ some mica					.3
(3)	5% ✓	0-17 17-37 37-57	msbk c wk sbk cl w/ some mica massive-wk sbk LSap	fr SSSP SEXP fr SSSP fr SSSP w/ some mica					.3
(4)	1% ✓	0-22 22-40 40-58	msbk c/cl wk sbk cl Massive LSap	fr SSSP SEXP fr SSSP w/ some mica - many gravel fr SSSP					.2

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Samuel Rollans & Brady Freeman
OTHER(S) PRESENT:

COMMENTS: