IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625

ARP 4664-78-4934 PERMIT # 207307

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4626298255

APPLICANT: Shea Homes APPLICANT ADDRESS: 8088 Corporate Center Charlotte, NC Ste 260

SITE ADDRESS: 146 Timberside Dr Davidson, NC PHONE: ALT. PHONE:

SITE DIRECTIONS: Shearers Rd TL Anniston Way TL Timberside on right

SUBDIVISION: Anniston SECTION: 3 LOT # 113 LOT AREA: .16Ac DESIGN FLOW: 480gpd L.T.A.R.: .3

Septic Tank	1000 (gal)	STB		Date 2-4-15	[X] New System	[ ] Repair	[ ] Expansion	System Type: I II III IV V VI	[X] Residence	No. Bedrooms 4	Water Supply: [X] Private
Pump Tank	1000 (gal)	PT		Date 2-14-15	System Description: Pump-1m-25% Reduction				[ ] Business	No. Persons 8	[ ] Public
Pump Make	Zoeller	Model	N-152	Serial #	Repair System Description: LP-PPBPS				[ ] Other	No. Employees	[ ] Community
# Nitrification Fields	1	# Lines	4	Linear Ft: 480	Maintenance Agreement Required:	[ ] YES	[X] NO		[ ] Slab	[X] Crawl Space	
Trench Width	36"	Max. Trench Bottom Depth	24-36"	Gravel Depth N/A		[ ] GRAVITY	[X] PRESSURE		[ ] Basement w/ plumbing	[ ] Basement w/o plumbing	

Comments / Conditions:

This permit replaces the previous permit dated 6-1-2015

INITIAL SITE SKETCH

See attached / approved plan by Michael Athanas & Assoc. dated July 6, 2015

* Maintain 15' from pool to septic.

AS BUILT SKETCH

	Date	Initials
Drain Lines Checked	7/10/15	SC
Tanks Checked	7/10/15	SC
Pressure Manifold or Valve Box Checked	7/10/15	SC
Pressure Head Set	7/10/15	SC
Electrical Checked	7/10/15	SC
Floats Set	7/10/15	SC
Alarm Checked	7/07/15	SC
Maintenance Contract Y / N		

21' Pressure Head Set. 7/10/15 SC

Installed Essentially As Drawn. Tanks Slightly Closer To Pool Area. Builder Signed Design Sheet.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

[ ] **IMPROVEMENT PERMIT** *with plat valid without expiration.* [X] **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* [X] **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 7/9/15 Installed by: Rowlan Septic

IMPROVEMENT PERMIT by: Date: 7/8/15 OPERATION PERMIT by: APPROVED JUL 27 2015

AUTHORIZATION TO CONSTRUCT by: Date: 7/8/15 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

Temporary Cul-De-Sac
S67°00'00"E
67.68'
N73°10'53"E 250.00'
S10°55'31"E
159.15'
House
Lot #113
0.757
Acres
32,995
Sq.Ft.
35' FS
35' RS
C19
C20
C21
C18
100'
S84°58'06"W
250.00'
Lot #114
0.754 Acres
32,825 Sq.Ft.
35' FS
35' RS
158.95'
S01°37'49"W
S83°14'41"E
247.82'
Pad To Be
15' From
Tanks Installed
N
Scale
1"=40'
APPROVED JUL 08 2015
341.38'
S01°44'04"W 412.55' Total