IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138105 PIN# 4664 68 9744.104 4664-79-0124 DATE Jan 16, 2007

OWNER OR APPLICANT Anniston LLC / Nichols PHONE: Business _____ Home _____

ADDRESS 17825 Statesville Rd, Suite 112, Cornelius, N.C. 28031

LOCATION Shoreward Rd (S) TL Timberside Dr. on left past Hanover Ct.

SUBDIVISION Anniston BLOCK / SECTION 3 LOT 104 LOT AREA 1.05Ac SITE CLASS. PS DESIGN FLOW 600gpd L.T.A.R. .25

Septic Tank: 1500 Gallons: STB 944 Date 12-2-0

Pump Tank: 1500 Gallons: PT 477 Date 7-20-0

Pump Make Gould's Model PE=5iM Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1365* Linear Feet 455*

No Lines 6* Trench Width 36"* Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other No. Bedrooms 5 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth NA ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* PER Plan Specs

70'X70' House footprint is all inclusive (ie includes deck, patio, etc.)

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

Comments:/Conditions: 5/32" hole drilled.

4/2/08 Tanks & lines Checked. Installed as drawn, except tanks see sketch

AS BUILT SKETCH

4/10/08 Set pressure 2ft & Checked alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Michael R. Riddell date 2-13-07

Improvement Permit by: _____ date 1-16-07

Authorization to Construct by: Judy Melville date 1-11-08

Installed by: Larry Hankle RS

Operation Permit by: Michael R. Dotson date 5/1/08

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK