IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 144345 PIN# 4664 79 2036, 107 4664-79-1790 DATE Sept. 14, 07

OWNER OR APPLICANT Anniston LLC / N. block PHONE: Business Home

ADDRESS 17824 Statesville Rd, Suite 112, Cornelius, NC 28031

LOCATION Shearwood & South TL Anniston Way TL Timberside Dr. go left at end

SUBDIVISION Anniston BLOCK / SECTION 3 LOT 107 LOT AREA 1.2Ac+, 35Ac SF SITE CLASS. PS SFE DESIGN FLOW 600gpd L.T.A.R. .275-.3

Septic Tank: 1500 * Gallons: STB 444 Date 8-19-08

Pump Tank: 1500 * Gallons: PT 447 Date 1-22-08

Pump Make: Gould's Model E2012HV Serial No.

Nitrification Field: No Fields 1 Square Feet 1095 * Linear Feet 365

No Lines 4 Trench Width 36" * Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PBBPS

Repair System Description: LP PBBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 5 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* PER plan specs
11/7/08 Checked tanks, lines, pressure & alarm

Comments:/Conditions: Drilled 5/32" hole

INITIAL SITE SKETCH

SEE Plan from Rollins Soil + Env. Services

AS BUILT SKETCH

Installed as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9-20-07

Improvement Permit by: date 9-14-07

Authorization to Construct by: date 8-13-08

Installed by: Larry Hendricks

Operation Permit by: Maintenance Tech date 12/12/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK