IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 1443597 20457 L

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4664-79-4557

APPLICANT: Shea Homes APPLICANT ADDRESS: 8008 Corporate Center Dr. Suite 300 Charlotte NC

SITE ADDRESS: 186 Timberside Dr Davidson NC 28036 PHONE: — ALT. PHONE: —

SITE DIRECTIONS: Sherards Rd. S, TL Anniston Way, TL Timberside, Site on R.

SUBDIVISION: Anniston SECTION: LOT # 109 LOT AREA: .78 Acre DESIGN FLOW: 480 GPD L.T.A.R.: .3 Initial/.25 Rec

Septic Tank	1000	(gal)	STB	825	Date	2/12/15	☑ New System	☐ Repair	☐ Expansion	System Type: I II III IV V VI	☑ Residence	No. Bedrooms	4	Water Supply	
Pump Tank	1000	(gal)	PT	302	Date	4/10/15	System Description: LPPPBPS				☐ Business	No. Persons	8	☑ Private	
Pump Make	Zoeller	Model	N153		Serial #		Repair System Description: LPPPBPS				☐ Other	No. Employees		☐ Public	
# Nitrification Fields		# Lines			Linear Ft:		Maintenance Agreement Required:	☑ YES	☐ NO		☐ Slab	☒ Crawl Space		☐ Community	
Trench Width	24"	Max. Trench Bottom Depth	36"		Gravel Depth	Sand		☐ GRAVITY	☑ PRESSURE		☐ Basement w/plumbing			☐ Basement w/o plumbing	

Comments / Conditions:

Installed As Drawn SL

INITIAL SITE SKETCH

See Attached / Approved Plan

By Michael Athanas E.

Assoc. APPROVED JAN 12 2015

AS BUILT SKETCH

	Date	Initials
Drain Lines Checked	6/11/15	SL
Tanks Checked	6/11/15	SL
Pressure Manifold or Valve Box Checked	6/11/15	SL
Pressure Head Set	6/11/15	SL
Electrical Checked	6/26/15	SL
Floats Set	6/11/15	SL
Alarm Checked	6/26/15	SL
Maintenance Contract (Y) N	6/29/15	SL

2' Head Pressure Set

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date: 1/23/15 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: [signature] Date: APPROVED JAN 12 2015 OPERATION PERMIT by: [signature] Dat 6/29/15

AUTHORIZATION TO CONSTRUCT by: [signature] Date: APPROVED JUN 11 2015 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

APPROVED JAN 12 2015

Lot #110
1.092 Acres
47,582 Sq.Ft.

Lot #109
0.954 Acre
41,569 Sq.Ft.

Scale
1" = 40'

N65°25'58"W 302.97

S63°15'57"E 267.56

S87°37'17"E 42.00

N33°30'04"E 126.03

S35°59'49"W 109.50

35' RS

35' FS

20' PSDE

24" RCP

L19

L12

L18

L17

C82

C2

Bm 63