IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 204270

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4664-97-8490

APPLICANT: Shea Homes APPLICANT ADDRESS: 8088 Corporate Center Ste 300 Charlotte NC

SITE ADDRESS: 298 Walking Horse Tr PHONE: ALT. PHONE:

SITE DIRECTIONS: Shearers S, TL on Anniston Hwy, TR on Burnell, TL on Walking Horse, Lot on R nearend

SUBDIVISION: Anniston SECTION: 4 LOT # 146 LOT AREA: 0.992ac DESIGN FLOW: 600gpd L.T.A.R.: 0.3

Septic Tank 1500 (gal) STB 1014 Date 11/5/14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5 Linear Ft: 500
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Grav. w/ 25% Reduction
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence ☐ Business ☐ Other ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing
No. Bedrooms 5 No. Persons 10 No. Employees

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: * Smooth terraces + complex topography within system + repair areas prior to installation,

8/8/14 Reviewed floor plans, in compliance with Septic plan. House is slightly wider but should still fit.

INITIAL SITE SKETCH

SEE DESIGN BY MICHAEL ATHANAS & ASSOCIATES

(APPROVED 6-24-14)

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/13/14 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 6-24-14 OPERATION PERMIT by: Richard Farris Date: 12/15/14

AUTHORIZATION TO CONSTRUCT by: Date: 8/8/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK


35' FS
45.95
123.94
C18
C19 N11°34'22"W 169.89 Total
C12
C13
C14
C20
C19 N11°34'22"E 169.89 Total
105.20
C10
C11 S11°34'22"E
64.69
Well
35' FS
DRIVE
35' FS
70'
Scale
1"=40'
ST
Pool
30'
304.27
N89°37'11"E
1.01 #146
0.992 Acre
43,194 sq. ft.
Gully
S78°25'38"W
289.45
Lot #145
0.842 Acre
36,674 sq. ft.
50,026 sq. ft.
395
102
110
98
98
502
Complex
Topo
177.17
24.14
15.03
APPROVED JUN 24 2014
ALP