IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 204270

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4664-97-8490

APPLICANT: Shea Homes APPLICANT ADDRESS: 8088 Corporate Center Ste 300 Charlotte NC

SITE ADDRESS: 298 Walking Horse Tr PHONE: ALT. PHONE:

SITE DIRECTIONS: Shearers S, TL on Anniston Hwy, TR on Burnell, TL on Walking Horse, Lot on R next end

SUBDIVISION: Anniston SECTION: 4 LOT # 146 LOT AREA: 0.992ac DESIGN FLOW: 600gpd L.T.A.R.: 0.3

Septic Tank 1500 (gal) STB 1014 Date 11/5/14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5 Linear Ft: 500
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Grav. 4y 25% Reduction
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 5
☐ Business No. Persons 10
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: * Smooth terraces * complex topography within system * repair areas prior to installation.

8/8/14 Reviewed floor plans, in compliance with Septic plan: House is slightly wider but should still fit. JJ

INITIAL SITE SKETCH

SEE DESIGN BY
MICHAEL ATHANAS
&
ASSOCIATES

(APPROVED 6-24-14)

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/13/14 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 6-24-14 OPERATION PERMIT by: Richard Farris Date: 12/15/14

AUTHORIZATION TO CONSTRUCT by: Maina M. Dotson RS Date: 8/8/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK