IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 149504

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4664-97-9218

APPLICANT: FRED GIGUAC / MIKE ATHANAS APPLICANT ADDRESS: 1999 CANDLEWICK DR.

SITE ADDRESS: 304 WALKING HORSE TR. PHONE: 704-576-3887 ALT. PHONE:

SITE DIRECTIONS: SHEARERS, TL ANNISTON, TR BURNELL, TL WALKING HORSE, END ON R

SUBDIVISION: ANNISTON SECTION: 4 LOT # 145 LOT AREA: .842 AC DESIGN FLOW: 480 L.T.A.R.: .25

Septic Tank 1000 (gal) STB 825 Date 9-23-13
Pump Tank 1000 (gal) PT 302 Date 9-23-13
Pump Make ZOELER Model N152 Serial #
Nitrification Fields 1 # Lines 7 Linear Ft: 320'
Trench Width 24-36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: LP- PANEL BLOCK
Repair System Description: SFE PANEL BLOCK
Maintenance Agreement Required: ☒ YES ☐ NO
☐ GRAVITY ☒ PRESSURE

☒ Residence ☐ Business ☐ Other ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing
No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

SEE ATTACHED PLAN
BY
MICHAEL ATHANAS
APPROVED BY ICHD

14 PANELS

AS BUILT SKETCH

INSTALLED
AS SHOWN
SET 2' PH
CHECKED LINES & TANKS

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 9-23-13 Installed by: ROWAN SEPTIC

IMPROVEMENT PERMIT by: Date: 4-9-13 OPERATION PERMIT by: Date: 12-11-13

AUTHORIZATION TO CONSTRUCT by: Date: 4-9-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK