4664-97-9715 COPY

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14903 PIN# 4664.98411O.148 Rollans DATE 3-20-08

OWNER OR APPLICANT Anniston LLC / Nblock Homes PHONE: Business (704) 278-0989 Home

ADDRESS 17824 Statesville Rd Ste 112 Cornelius, NC 28031

LOCATION Shearers Rd South, TR Anniston Hwy, TR Burnett Place TR, in walking Horse on right near end

SUBDIVISION Anniston BLOCK / SECTION 2 LOT 148 LOT AREA 1.45Acre SITE CLASS. PS DESIGN FLOW 600 L.T.A.R. .3

Septic Tank: 1500 Gallons: STB 338 Date 1-5-11

Pump Tank: ~~1500~~ Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1500 Linear Feet 500'

No Lines 5@100' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity - 25% Reduction

Repair System Description: Pump-Panel BIK

Maintenance Agreement Required: ☐ Yes ☒ No

Gravel Depth N/A ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 5

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions: Initial site evaluation performed by Rollans Soil & Environmental Services

Comments/Conditions: 1/28/11 Reviewed Floor plans & Site plan and is in compliance with original permit.

X Note: Floor plans only show 3 Bedrooms

INITIAL SITE SKETCH

Seen attached report by Rollans Environmental for Specs

AS BUILT SKETCH

INSTALLED ARE 3&6

TOP 4 LINES = 102'

BOTTOM LINE = 82'

AS BUILT ATTACHED

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 3/28/08 Installed by: LARRY HINKLE

Improvement Permit by: Maria H. Nelson RS date 3/19/08 Operation Permit by: RS date 4-7-11

Authorization to Construct by: Maria H. Nelson RS date 1/27/11 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK