IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 078465 PIN# 4665239005 DATE Feb. 19, 99

OWNER OR CONTRACTOR James MacKnight II Piedmont Housing PHONE: Business Home

ADDRESS 255 Rolling Hills Rd. Mooresville

LOCATION Shepherds Rd S. TR Ashley Woods Dr. Bear Right at End 192 Ashley Woods Dr.

SUBDIVISION Ashley Woods BLOCK / SECTION LOT Tract A (2) LOT AREA 1.305 Ac SITE CLASS. RS DESIGN FLOW 360gpd L.T.A.R. .225

Septic Tank: 1000 Gallons; STB 1012 Date 11/17/98

Pump Tank: 1000 Gallons; PT 17 Date 1/22/99

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1260 Linear Feet 420

No Lines 6 @ 70' Trench Width 36" Max Trench Bottom Depth 18" Gravel Depth

☑ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: pm- cultec 100 OR (HD) 2012 HORIZ.

Repair System Description: Same

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ Public ☑ Community

Comments:/Conditions:

250.82

1"=50'

INITIAL SITE SKETCH

24' Detached Garage 40'

276.95'

76'

DW MH 28'

ST PT

4" Sch 40 P.V.C.

Repair Area

10'

Driveway

29716'

Water Line Route

Graded Area

Comments:/Conditions: Installer note max. trench bottom depth.

* One inspection port per lateral. Locate drainfield exactly where shown (ie within 20' of side line of lot 12.

Do not dissect septic area with any utility lines.

AS BUILT SKETCH

420

÷ 6

252.0

Lot 12

No Ashley Woods Drive

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 2-12-99 Installed by: A-1 Backhoe

Improvement Permit by: date 2-12-99 Operation Permit by: Wesley Sparks RS. date 4/21/99

Authorization to Construct by: date 2-12-99 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK