4665298961

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Rummage DATE 12-20-76 PERMIT NO. 307

PHONE: Business _____ Home 664-2171

LOCATION 1125 I 2 on 1187 5th house on right

S. R. No. _____

SUBDIVISION NAME Woodcrest LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area Existing

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 5% slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank Existing Gals.
Washing Machine Line
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hancock DATE 12-20-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold