DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: James McKnight APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12/3/9
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot #33 Ashley Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed Com well

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1950 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 5%	0-48"	Rd/Brn C/SCL	mSBK SS,SP,SE,FI-FR					PS .3
2	L 8%	0-48"	Rd/Brn C/SCL	mSBK SS,SP,SE,FI-FR					PS .3
3		0-8"	Brn SCL A-FR						PS .3+
		8"-48"	Rd/Brn C	SBK SS,SP,SE,FR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____