09112

4665350764

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J.C. Miles DATE 9/26/89 ~~PERMIT~~ NO. 21D

PHONE: Business _____ Home _____

LOCATION 1125 S. past jct with 1136 TR Smyrna Lane at end on left S. R. No. _____

SUBDIVISION NAME ? LOT NO. 7 SECTION OR BLOCK NO. 1D-C-70 Caddle Creek

House ( ) Mobile Home (✓) Business ( ) Other w/ detatched garage

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000 ft²+

Character & Porosity of Soil Clay


Percolation Rate ~.35gpd/ft²

Topography ~10%

Depth to Water Table 3'+

Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 690 Linear Ft. 230+

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David R. Hinson, P.S.

COMMENTS: PROPERTY LINE.

CERTIFICATE OF COMPLETION BY Andre C Pierce DATE 4/26/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold