4665-42-1193

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald G. Ervin DATE 12-17-85 PERMIT NO. 528

PHONE: Business _____ Home _____

LOCATION 1255 on R across from AME Zion Church TR dirt street 4th on left S. R. No. _____

SUBDIVISION NAME Wildwood Acres LOT NO. 4 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )
Lot Area 20,000+ 12 Drive

Character & Porosity of Soil Clay loam - clay
Percolation Rate 0.5 gal/ft/day
Topography 2 4
Depth to Water Table 4
Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by F. J. Ervin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 12-17-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold