IREDELL COUNTY HEALTH DEPARTMENT 4665425520

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lewis M. Edmiston DATE 6-20-86 PERMIT NO. 354

PHONE: Business _____ Home _____

LOCATION 1125S TR before Johnson Dairy Rd Wildwood Acres
2nd lot on Right S. R. No. _____


SUBDIVISION NAME Wildwood Acres LOT NO. 28? SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000 sq ft

Character & Porosity of Soil clay
Percolation Rate .4 gal/sq ft/day
Topography 2-8%
Depth to Water Table 41"
Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Charles K. Bennett

COMMENTS: well not down yet

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 6-20-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold