IREDELL COUNTY HEALTH DEPARTMENT 4606552 7029

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George D. Branson DATE 11-2-84 PERMIT NO. 417

PHONE: Business _____ Home _____

LOCATION 1125 S on left below 1147, TL Spring Lane Lane 3rd Lot on R (600 ft from Road)

SUBDIVISION NAME Timberview LOT NO. 25 SECTION OR BLOCK NO. 1125

House ( ) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes ( ) No (X)
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Lot Area _____

Character & Porosity of Soil Clay
Percolation Rate 0.5 gal/ft²/day
Topography Level
Depth to Water Table 48
Rock or other impervious formations Numerous outcroppings

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 3
No. of Lines
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by F. J. Erwin Co

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 11-2-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold