Lot 50 Timberview

① Pump to ponds - 42" soil depth to work with, limited area - replacement
② Mostly depressional except for middle right side (drainfield)
3. MH may be located where flagged off
4. Well must go in front of home, outside road right of way
5. Surface water runoff management of utmost importance, topography competes with proper absorption field functioning must have diversion ditching

ie.